# Contents

- <u>1 How It Works</u>
- 2 Characteristic Features of Connection to KNX via the BAOS Protocol
- <u>3 Preparation of Data in ETS for Their Import in iRidium</u>
  - <u>3.1 Preparation of Projects in ETS</u>
  - <u>3.2 Setting up Datapoints in ETS</u>
  - 3.3 Import of Datapoints from ETS to iRidium
  - 3.4 Creation of KNX IP BAOS and Lists of Datapoints in the Manual Mode
- <u>4 Properties of Connection to KNX IP BAOS</u>
  - <u>4.1 Connection to KNX IP BAOS in the Local Network</u>
  - <u>4.2 Connection to KNX IP BAOS via the Internet</u>
  - <u>4.3 Switching Between the Local and Internet Connection</u>
- <u>5 Controlling KNX IP BAOS Datapoints in iRidium Projects</u>
  - <u>5.1 Driver Tokens</u>
  - <u>5.2 Commands</u>
  - <u>5.3 Feedbacks</u>
- <u>6 Emulation of Project Work</u>
- <u>7 Launching Projects on Control Panels</u>

## **How It Works**

For connecting to the KNX bus through KNX IP BAOS iRidium clients can use the Object Server protocol.

Connection to the bus through <u>KNX IP BAOS 771/772</u> routers via the BAOS (Bus Access and Object Server) protocol.

This mode uses intermediate addresses (Datapoints) which have to be set up in ETS for connection to the bus.



### Number of connections to the bus:

up to 10 (in practice up to 5 at full load) panels can connect to KNX through KNX IP BAOS 771/772 via the BAOS protocol (locally or via the Internet) at a time. The maximum number of

connections depends on the amount of the transferred data and it does not exceed 10. It is required to set up intermediate addresses in ETS to work via the BAOS protocol.

#### Licensing:

Device License (KNX), Device License Pro (KNX), Site License (BAOS), Site License Pro (BAOS). <u>More >></u>

# **Characteristic Features of Connection to KNX via the BAOS Protocol**

When setting up projects in ETS and setting up Wi-Fi network on the automation site you should consider the characteristic features of work with KNX IP BAOS 771/772:

A iRidium control panels and KNX IP BAOS should be in one IP subnetwork.

A When selecting the model of KNX IP BAOS (771 or 772), make sure it supports the required number of Datapoints:

KNX IP BAOS 771 supports up to 250 Datapoints per 1 router (you will be able to work with 250 group addresses through them). Up to 2000 group addresses. Datapoints have to be activated only for those group addresses which the control panel will work with.
KNX IP BAOS 772 supports up to 1000 Datapoints per 1 router (you will be able to work with 1000 group addresses through them). Up to 2000 group addresses.

▲ For activation of iRidium projects the forced request of group addresses in the KNX bus is used. It is performed at each start of iRidium projects. To see the status of group addresses at the project start mark "Read" in the properties of each address in ETS. <u>More >></u>

**A** Use Wi-Fi repeaters when organizing the local network to have stable connection between the control panels and the router.

A If you use all router Datapoints, do NOT connect more than 5 panels to one BAOS.

A Remove all addresses you do not need to control (or which status you don't need to receive) from your iRidium project for KNX IP BAOS. If the address is available for reading only, delete commands for this address (Commands). If the address is available for writing only, delete feedback channels (Feedback) for this address. It will help to reduce the load on the router and the bus.

Contact iRidium <u>Support Team</u> to receive more detailed instructions.

# **Preparation of Data in ETS for Their Import in iRidium**

Before creating a visualization project, make sure the KNX equipment is set up and the ETS project is ready for import. After that you can proceed.

#### **Preparation of Projects in ETS**

Assign the "[ $\checkmark$ ] **Read**" flag to the group addresses which status should be received at the start of iRidium projects. It affects only the receipt of the status at the project start (it does not affect event updates):



Save the project file in the ETS3 or ETS4 format (\*.pr3, \*.pr4, \*,pr5, \*.knxproj, \*.csv) for its import in <u>iRidium GUI Editor</u>.

After the project saving, close the ETS program, if the used KNX IP router does not support >1 connection at a time. Otherwise iRidium cannot connect to the bus.

#### <u>↑ Back</u>

#### **Setting up Datapoints in ETS**

Setting up of Object Server is performed in ETS. Ready group addresses are related to Datapoints – intermediate addresses of KNX IP BAOS.

To set up relation between KNX group addresses and BAOS objects:

1. Add the KNX IP BAOS interface in the list of ETS connections and select it as a working one:

				Ô		•				
Overview	Projects	Catalogs	Database	Settings						
Presentation General	<b>(</b>									
Presentation Languag	ion Language									
Communication Enable automatic scan on serial ports										
Database	🗹 Use proje	Use project connection if available								
Software Updates	Currently se	lected:				*				
Troubleshooting	KNX IP I	BAOS 771								
Import	Configured	connections								
Shortcuts	📥 KNX I	P BAOS 771 - 192.168.	0.163 (IP)							
	Individual	Individual address: 15.15.250								
	IP address	192.168.0.163	_	<b>T</b>						
		Test Select Local settings								
	କ୍ଟେ USB (	Contraction of the second seco								
	Discovered	Discovered connections								
	🕮 Ather	Atheros AR5B95 Wireless Network Adapter (2) - 224.0.23.12 (IP-Routing)								
						Ŧ				
				New	Delete Edit					

2. Select KNX IP BAOS in the "Topology" list and open the "Parameters" ("Edit Parameters") tab. In the General item select the name of KNX IP BAOS and use of the static IP-address (for connection to Object Server addresses of the IPv4 standard are used):

Topology 🔻	_			i • •	
🕂 Add Devices 👻 👗 Delete	Show Parameter Changes	Find	<mark>,</mark>		
▲ III Topology	Device: 1.0 KNX IP BAOS 77				
Dynamic Folders	General IP configuration 1				
4 🔡 0 Backbone area			Device name	KNX IP BAOS 771	
🗄 0.0 Backbone line	IP configuration 2		IP address assignment	static	•
4 🔡 1 New area	Data points 1 - 5				
1.0 Main line	Data points 6 - 10		Download of dat descriptions	Activated	•
▶ 1.0 KNX IP BAOS 771	Data points 11 - 15				
1.1 New line	Data points 16 - 20				
	Data points 21 - 25				
Find 🔎 🔇 🗅 0/0 🏶 🗸	Devices / Parameters / (	Comm	nissioning /		

3. Go to "IP Configuration 1" and set up the IP-address of the KNX IP BAOS interface (in "IP Configuration 2" the subnet mask and the gateway address are indicatd by default):

Topology 🔻	_	_	_		₽ <sup>⊭</sup> * ×
🕂 Add Devices 👻 👗 Delete		Find	<u></u>		
🔺 🛄 Topology	Device: 1.0 KNX IP BAOS 771				
Dynamic Folders	General	TD address			
<ul> <li>Backbone area</li> </ul>	IP configuration 1	IP address			
🗄 0.0 Backbone line	IP configuration 2	Byte 1	192		
4 🔡 1 New area	Data points 1 - 5	Byte 2			
🔺 🗄 1.0 Main line	Data points 6 - 10		168		
▷ 1.0 KNX IP BAOS 771	Data points 11 - 15				
1.1 New line	Data points 16 - 20	Byte 3	0		
	Data points 21 - 25	Dute 4	05		
	Data points 26 - 30	Byte 4	65		
	Data points 31 - 35				
Find P < > 0/0 🏶 -	Devices / Parameters / Commission	oning /			

4. In the "Data Points 1...n" tab intermediate addresses are activated and set up. Properties: name and data type of the address the Datapoint is related to:

Topology 🔻			
🕂 Add Devices 👻 👗 Delete	Show Parameter Changes Defaul	t parameters	Find 🔎 🌱
Topology	Device: 1.0 KNX IP BAOS 771		
Dynamic Folders	General	A	1.0%
🔺 👫 0 Backbone area	IP configuration 1	I lype of data point 1	1 Bit 👻
🗄 0.0 Backbone line	IP configuration 2	Description of data point 1	D1 Relay 1
4 🔡 1 New area	Data points 1 - 5		
🔺 📙 1.0 Main line	Data points 6 - 10	Type of data point 2	1 Bit 👻
1.0 KNX IP BAOS 771	Data points 11 - 15	Description of data point 2	D2 Belay 2
1.1 New line	Data points 16 - 20	Description of data point 2	
	Data points 21 - 25	Type of data point 3	2 Bytes 👻
	Data points 26 - 30		
	Data points 31 - 35	<ul> <li>Description of data point 3</li> </ul>	D3 Dimmer 1
Find 🔎 🗘 🖒 0/0 🏶 🗸	Devices / Parameters / Commis	sioning /	

5. The set up Datapoint is related to the corresponding group address (or addresses) by dragging it from the "Topology" window to "Group Addresses":



When the relation is established save the project file in the ETS3 or ETS4 format (\*.pr3, \*.pr4, \*,pr5, \*.knxproj, \*.csv) for its import in <u>iRidium GUI Editor</u>.

#### **Important!**

Set up Datapoints beforehand as in <u>iRidium GUI Editor</u> BAOS with Datapoints will be displayed as a separate device (KNX IP BAOS) with its list of addresses. If you first set up group addresses and assign them to GUI, then when transferring to Datapoints all assigns should be made again.

<u>↑ Back</u>

#### Import of Datapoints from ETS to iRidium

You can import the list of Datapoints with all settings formed in ETS to <u>iRidium GUI Editor</u>. It will allow you to set up control of the bus equipment fast. Create a new project in <u>iRidium GUI Editor</u>, then select "File" > "Import":

III P	roject 1		
File	Project Tools Help 🕴 😫 🚞	• 🖺 🖺 👪 🗉 🖌	
B	New Project Ctrl+N	r IIII Onen	
	Open Project Ctrl+O		1012 5 1
	Save Project Ctrl+S	Colorad Disk (D:)	<ul> <li>KNX Projects</li> </ul>
	Save Project As	Organize 🔻 New folder	
E.	Close Project Ctrl+F4	Name	Date modified
<b>1</b>	Close All Projects		05.00.0010.10.15
	Peoper	Project 1.pr3	05.03.2012 19:15
		Project 2.pr4	24.01.2011 16:04
	Import	Project 3.pr5	10.03.2012 2:39
D	Exit		

The tool of import forms the list of gateways and their intermediate addresses. You can select BAOS to work via Datapoints or KNX IP Router to work via group addresses (KNXnet/IP):



### **Important!**

When importing datapoints from an ETS project names are formed on the bais of data in the Description field. If the Description field is empty, the datapoint name will look as follows: "Datapoint ..."

If you do not have the ETS where you can import the data from, you can create gateways and addresses manually:

### Creation of KNX IP BAOS and Lists of Datapoints in the Manual Mode

If you don't have the ETS project from which you can import the addresses, create a KNX IP router and the list of addresses manually.

Select the KNX Router device (KNXnet/IP) in the "DEVICE BASE" window of GUI Editor and drag it into "PROJECT DEVICE PANEL" window.



<u>↑ Back</u>

# **Properties of Connection to KNX IP BAOS**

You can set up local or external connection for KNX IP BAOS – to work in the home/office Wi-Fi network or via the Internet.

To set up properties of connection to BAOS, open the upper level of the device tree:

**Connection to KNX IP BAOS in the Local Network** 

PROJECT DEVICE PANEL		Ŀ:					
🕀 🕶 🔁 🗧	🚥 👱 🗧	3					
<ul> <li>System Tokens</li> <li>Project Tokens</li> <li>Drivers</li> <li>KNX IP BAOS 77</li> <li>Driver Tokens</li> <li>Commands</li> <li>Feedback</li> </ul>	<ul> <li>System Tokens</li> <li>Project Tokens</li> <li>Drivers</li> <li>Imm KNX IP BAOS 771/772</li> <li>Driver Tokens</li> <li>Commands</li> <li>Feedback</li> </ul>						
PROPERTIES							
Name Driver Type	KNX IP BAOS 771/772 BAOS 771/772 (TCP)						
Host Port Update time	192.168.0.100 12004 0						

 ${\bf Host}$  – the local IP-address of the KNX IP BAOS router

Port - the port of connection to the router (it is 12004)

**Update Time** (ms) - the frequency of sending the Ping command for confirming the connection with the router. 0 - by default, > 5000 ms - if you want to set it manually.

<u>↑ Back</u>

#### **Connection to KNX IP BAOS via the Internet**

For working via KNXnet/IP via the Internet:



 ${\bf Host}$  – the public IP-address of the KNX IP BAOS router

Port - the public port of connection to the router

**Update Time** (ms) – the frequency of sending the Ping command for confirming the connection with the router. 0 - by default, > 5000 ms - if you want to set it manually.

Set up <u>Port Forwarding</u> on the router for remote control.

↑ Back

#### Switching Between the Local and Internet Connection

If the control panel should hold the connection with the system when the panel is out of the limits of the Wi-Fi network of the system, you need to set up the switch between the Internet and the local network.

The remote mode suggests connection to the system via the Internet. At that the external IP-address or the domain name of the system to which you need to connect have to be used.

**A** In iRidium Wi-Fi/3G CANNOT be switched automatically. For switching between the Internet and the local network you need buttons with special settings. See the settings below.

A To control the system remotely you have to open the system for external access - to set up <u>the Port Forwarding Service</u>.

**A** To secure equipment from unauthorized access we recommend using secure connection with the remote system (VPN).

### Setting up of the switch Wi-Fi/3G in iRidium projects:



**1.** Open the script editor in iRidium GUI Editor.

**2.** Download and add into your project the template of the Wi-Fi/3G switch (Add Script from file): **download the template of the Wi-Fi/3G switch** 

The Wi-Fi/3G switch is performed with the help of the script function SetParameters

Setting up of parameters of the Wi-Fi/3G switch:

```
function Internal_1() // Function name
IR.GetDevice('KNX BAOS 771/772').SetParameters({Host: "192.168.0.163", Port:
"12004", UpdateTime: "0"}); // Driver Name + Parameters
```

```
}
```

```
function External_1()
```

```
{
```

{

```
IR.GetDevice('KNX BAOS 771/772').SetParameters({Host: "210.110.10.10", Port: "12004", UpdateTime: "0"});
```

```
}
```

Indicate in the command settings:

- Function name the name of the switch function (command). Two functions cannot have the same name in a project.
- Driver Name the name of the driver which parameters are changed
- Parameters the set of the switch parameters which you need to apply to the driver

Assign commands to buttons:

- 1. Select the button which will be responsible for the Wi-Fi/3G switch.
- Open the properties of the button: Object Properties > Programming
- 2. Open <u>Macros Editor</u> of the button for the Press or Release events
- 3. Select the  $\ensuremath{\textbf{Script}}\xspace$  Call command and add it by double-clicking on it
- 4. Select the name of the function you want to activate in the drop-down list. Create the command.

ER Advanced_r	econnect_	× 150			- DunTegr
OBJECT PROPERTIES			Wi-Fi / 3G reconnection	Macros Editor On Release Event	
General	Programming	States 200		Macros	Commands
UGHERAL O Collections (0) Preass (1) Release (1) Release (1) Release (1) Scytt Coll (0) Hold (0) Hold (0) Move	Internal_1	544465 250	Choose connection mode: Wi-Fi (Local) 3G (Inet)	x +	

Set up access to the equipment from the Internet:

In order to do that <u>open the equipment ports for remote access</u>.

#### ↑ Back

# **Controlling KNX IP BAOS Datapoints in iRidium Projects**

In iRidium projects a KNX IP BAOS consists of 3 parts:

- Driver Tokens the list of variables which store information about connection to BAOS.
- **Commands** the list of datapoints available for writing.
- Feedbacks the list of datapoints available for reading.

They have the following properties and application:

#### **Driver Tokens**

**Driver Tokens** are the variables where the status of connection to the controlled KNX IP BAOS router is stored. The properties can be read only. To use the driver variable drag it on a graphic item. (the value can be output in the item text field or it can be used to affect the item state)



- **Online** the state of connection to the controlled system (Online/Offline = 1/0)
- **Status** the status of connection to the system (Offline/Connect/Online/Disconnect = 0...3)
- **Host** the domain name of the remote system

HostPort the port of the remote system to which iRidium App connects

- IP the IP-address of the control panel
- HostIP the IP-address of the remote system to which iRidium App is connected
- **Port** the client local port through which connection to the remote device is performed

#### Commands

<u>**Commands**</u> – it is the list of group addresses available for writing.

These are commands for sending numbers and strings to Datapoints. A command is assigned to the graphic item which can write data to the corresponding address with the help of this command.

<ul> <li>► BAOS 771</li> <li>▲ Tokens</li> <li>■ Commands</li> <li>▲ Relay 1</li> <li>④ Feedback</li> </ul>						
CHANNEL	PROPERTIES					
Name		Relay 1				
Туре		1 bit				
SubType		SWITCH				
Address		1				
Command		Set value and send on bus				

#### Commands

Namethe command name, at randomTypethe data typeSubTypethe data subtype (measurement units, regulation limits)Addressthe intermediate address (Datapoint)

To assign a command to a graphic item drag it on the graphic item and select the properties of command assigning. At that be guided by the group address type, the graphic item type and the desirable way of control:

### Go to examples of controlling equipment in the KNX bus>>

#### Feedbacks

**Feedbacks** – it is the list of group addresses available for reading.

A feedback channel receives the value from a particular address in the KNX bus. The received value can be output on graphic items. *Remove channel from which you do not need to receive feedback in the Feedbacks tab – it will reduce the load on the bus at the project launch.* 

	Analog / Temp ASCII String R G B				
Brightness					
PROPERTIES					
Name		Analog / Temp			
Туре		Float 16 bit			
SubType		Temperature C			
Address		6			

#### Feedbacks

Namethe command name, at randomTypethe data typeSubTypethe data subtype (measurement units, regulation limits)Addressthe intermediate address (Datapoint)

To assign a status channel to a graphic item drag it on the graphic item and select the properties of channel assigning. At that be guided by the group address type, the graphic item type and the desirable way of control:

<u>Go to examples of controlling equipment in the KNX bus>></u>

#### <u>↑ Back</u>

## **Emulation of Project Work**

#### Emulator

- is an iRidium application for Windows which can be launched from GUI Editor for testing your projects. Emulator can work both with a license (with connection to the equipment) and without it (when only the project graphic part is functional).

**Operation modes for Emulator** (see GUI Editor > Tools > Options > Emulator):

**Without the license** (Demo Mode: on) – no connection with the controlled equipment. **With the license** (License Path: [...]) – when the <u>license file</u> is selected, all Emulator functions work and there is connection with the controlled equipment.

**Indicate the path to the** <u>license file</u> **for Emulator** (GUI Editor > Tools > Options > Emulator):

💥 il	Ridium G	UI Edi	itor												
File	Project	Tool	s Help	View 🕴 😫		-	🗒 🌬 🗉 🛓	1 🚈 🕨	Emulat	or 🛹 Sen	id To Panel				
Pages تتر	PROJEC	-	Languag Options Certificat Default P	e tes Panels Sizes	•		Options Emulator Client License	Showin	g	Scan	File Operat	ing De	fault Con	× 1t	<b> </b> -
s Overview 🚺 Gallery							License Path: Client Fullscreen Client Sound On: Show Log at Emu	: Iator start:	D:\Lice	nses\My_PC	C.irl		Cancel		
						l									

\* When **Demo Mode** is activated Gui Editor won't show the message about starting without the connection to the controlled equipment (without a license). Check if there is a license when setting up your project.

#### **Emulator hot keys**

Click F5 to start Emulator. Click F8 to open <u>the Emulator settings</u> (password: 2007) Click F4 to open the Emulator log.

For **fully functional work** of iRidium on your PC it is required <u>to get</u> an iRidium license and <u>activate</u> it for <u>for your PC</u>.

Activation of licenses for iPad/iPhone/Mac/Android based or other devices does NOT lead to the automatic licensing of the PC with the installed iRidium Environment. A license for your PC is required for iRidium client on your PC (including Emulator) to work in the fully functional mode. The license should be purchased separately or you can use free For testing purposes you can use free <u>licenses</u>).

### Logging in Windows

A



**iRidium Log** is a window where information about iRidium work, error messages and iRidium Script logs (IR.Log) are output in the text format.

To open the iRidium log in Windows, click **F4**.

<u>↑ Back</u>

## **Launching Projects on Control Panels**

Uploading and launching of iRidium projects on control panels are performed with the help of the <u>iRidium Transfer</u> application installed on your PC. You can also upload your project on the panel from GUI Editor with the help of Transfer.

- Instructions for setting up properties of the iRidium project launch on control panels: **Properties for Launching iRidium Projects**
- Instructions for uploading iRidium projects on control panels: iRidium Transfer.
- Instructions for setting up iRidium projects on control panel: **iRidium App**

<u>↑ Back</u>

Go to examples of controlling equipment in the KNX bus via KNX IP BAOS >>

<u>↑ Back</u>